

GOVERNMENT OF TRIPURA  
OFFICE OF THE DIRECTOR FIRE SERVICE  
TRIPURA, AGARTALA

No. 3065-66/3-8/TFS/2017

Dated, Agartala, the 16th February, 2017

To  
The Secretary,  
Swami Hitakamananda,  
" Ram Krishna Mission Vidyalaya",  
Viveknagar, Tripura West,  
Phone : (0381) 237 0333/4222.  
E-Mail : vidyaviveka@gmail.com  
Pin -799 130.

Sub :- Issuing of NOC on Fire Safety arrangement in the " Ram Krishna Mission Vidyalaya", Viveknagar, Tripura West.


Dear Sir,

Please refer to your letter F.No.247/RKM/VLYA/CBSE dated 06 January, 2017 on the subject mentioned above.

It is to inform you that the fire fighting arrangement as installed in the building premises of " Ram Krishna Mission Vidyalaya", Viveknagar, Tripura West is presently adequate.

The existing fire fighting arrangement should be checked by your own trained staff from time to time and if they find any defect that should be replaced or repaired immediately. The " Ram Krishna Mission Vidyalaya" authority should communicate this Office after every 6 months for fire audit to ensure the fire fighting equipments are in good condition.

Yours sincerely,


  
(Uttam Kr. Bhawmik, IPS)  
Joint Director,  
For Director Fire Service,  
Tripura Agartala.

Attested  
16/2/17  
Principal, Ram Krishna Mission Vidyalaya, Viveknagar, Tripura West

Copy to :-

1. The Divisional Fire Officer, West Tripura District, Agartala for information. This refers to his no. 1017/ 3-8/ Fire(W)/2017 Dated 13.02.2017.

**ATTESTED**

  
Principal,  
RAMAKRISHNA MISSION VIDYALAYA  
P.O:Viveknagar, Tripura  
PIN-799130